## SIEMENS

## Data sheet

## 6ES7215-1HG40-0XB0



SIMATIC S7-1200, CPU 1215C, compact CPU, DC/DC/relay, 2 PROFINET ports, onboard I/O: 14 DI 24 V DC; 10 DO relay 2 A, 2 AI 0-10 V DC, 2 AO 0-20 mA DC, Power supply: DC 20.4-28.8 V DC, Program/data memory 125 KB

General information	
Product type designation	CPU 1215C DC/DC/relay
Firmware version	V4.5
Engineering with	
Programming package	STEP 7 V17 or higher
Supply voltage	
Rated value (DC)	
• 24 V DC	Yes
permissible range, lower limit (DC)	20.4 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Load voltage L+	
<ul> <li>Rated value (DC)</li> </ul>	24 V
<ul> <li>permissible range, lower limit (DC)</li> </ul>	20.4 V
<ul> <li>permissible range, upper limit (DC)</li> </ul>	28.8 V
Input current	
Current consumption (rated value)	500 mA; CPU only
Current consumption, max.	1 500 mA; CPU with all expansion modules
Inrush current, max.	12 A; at 28.8 V DC
l²t	0.8 A <sup>2</sup> ·s
Output current	
for backplane bus (5 V DC), max.	1 600 mA; Max. 5 V DC for SM and CM
Encoder supply	
24 V encoder supply	
• 24 V	L+ minus 4 V DC min.
Power loss	
Power loss, typ.	12 W
Memory	
Work memory	
<ul> <li>integrated</li> </ul>	125 kbyte
expandable	No
Load memory	
• integrated	4 Mbyte
<ul> <li>Plug-in (SIMATIC Memory Card), max.</li> </ul>	with SIMATIC memory card
Backup	
• present	Yes
maintenance-free	Yes
without battery	Yes
CPU processing times	
for bit operations, typ.	0.08 μs; / instruction

for word operations, typ.	1.7 µs; / instruction
for floating point arithmetic, typ.	2.3 µs; / instruction
CPU-blocks	2.0 µ3,7 monution
Number of blocks (total)	DBs, FCs, FBs, counters and timers. The maximum number of
	addressable blocks ranges from 1 to 65535. There is no restriction, the entire working memory can be used
OB	
• Number, max.	Limited only by RAM for code
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	14 kbyte
Flag	
• Size, max.	8 kbyte; Size of bit memory address area
Local data	
• per priority class, max.	16 kbyte; Priority class 1 (program cycle): 16 KB, priority class 2 to 26: 6 KB
Address area	
Process image	
<ul> <li>Inputs, adjustable</li> </ul>	1 kbyte
Outputs, adjustable	1 kbyte
Hardware configuration	
Number of modules per system, max.	3 comm. modules, 1 signal board, 8 signal modules
Time of day	
Clock	
Hardware clock (real-time)	Yes
Backup time	480 h; Typical
Deviation per day, max.	±60 s/month at 25 °C
Digital inputs	
Number of digital inputs	14; Integrated
of which inputs usable for technological functions	6; HSC (High Speed Counting)
Source/sink input	Yes
Number of simultaneously controllable inputs all mounting positions	
— up to 40 °C, max.	14
Input voltage	
Rated value (DC)	24 V
• for signal "0"	5 V DC at 1 mA
● for signal "1"	15 V DC at 2.5 mA
Input delay (for rated value of input voltage)	
for standard inputs	
— parameterizable	Yes; 0.2 ms, 0.4 ms, 0.8 ms, 1.6 ms, 3.2 ms, 6.4 ms and 12.8 ms, selectable in groups of four
— at "0" to "1", min.	0.2 ms
— at "0" to "1", max.	12.8 ms
for interrupt inputs	
— parameterizable	Yes
for technological functions	
— parameterizable	Single phase: 3 @ 100 kHz & 3 @ 30 kHz, differential: 3 @ 80 kHz & 3
Cable length	@ 30 kHz
Cable length <ul> <li>shielded, max.</li> </ul>	500 m; 50 m for technological functions
<ul> <li>unshielded, max.</li> </ul>	300 m; for technological functions: No
Digital outputs	
Number of digital outputs	10; Relays
Switching capacity of the outputs	io, isolayo
with resistive load, max.	2 A
• on lamp load, max.	30 W with DC, 200 W with AC
Output delay with resistive load	
• "0" to "1", max.	10 ms; max.
• "1" to "0", max.	10 ms; max.
Relay outputs	
<ul> <li>Number of relay outputs</li> </ul>	10
<ul> <li>Number of operating cycles, max.</li> </ul>	mechanically 10 million, at rated load voltage 100 000
Cable length	

• shielded may	500 m
<ul> <li>shielded, max.</li> <li>unshielded, max.</li> </ul>	500 m 150 m
	150 11
Analog inputs	
Number of analog inputs	2
Input ranges	Vee
Voltage     Input ranges (rated values), voltages	Yes
• 0 to +10 V	Yes
- Input resistance (0 to 10 V)	≥100k ohms
Cable length	21000 011113
• shielded, max.	100 m; twisted and shielded
Analog outputs	
	2
Number of analog outputs Output ranges, current	2
• 0 to 20 mA	Yes
Analog value generation for the inputs	
Integration and conversion time/resolution per channel	
<ul> <li>Resolution with overrange (bit including sign), max.</li> <li>Integration time, parameterizable.</li> </ul>	10 bit
<ul> <li>Integration time, parameterizable</li> <li>Conversion time (per channel)</li> </ul>	Yes 625 µs
Conversion time (per channel)	020 μο
Analog value generation for the outputs	
Integration and conversion time/resolution per channel	
Resolution with overrange (bit including sign), max.	10 bit
Encoder	
Connectable encoders	
2-wire sensor	Yes
1. Interface	
Interface type	PROFINET
Isolated	Yes
automatic detection of transmission rate	Yes
Autonegotiation	Yes
Autocrossing	Yes
Interface types	
• RJ 45 (Ethernet)	Yes
Number of ports	2
integrated switch	Yes
Protocols	
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
<ul> <li>Open IE communication</li> <li>Web server</li> </ul>	Yes; Optionally also encrypted Yes
<ul> <li>Web server</li> <li>Media redundancy</li> </ul>	Yes
PROFINET IO Controller	
Transmission rate, max.	100 Mbit/s
Services	
— PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
— Isochronous mode	No
— IRT	No
— PROFlenergy	No
— Prioritized startup	Yes
— Number of IO devices with prioritized startup,	16
max.	
<ul> <li>— Number of connectable IO Devices, max.</li> </ul>	16
<ul> <li>— Number of connectable IO Devices for RT,</li> </ul>	16
max.	10
— of which in line, max.	16
<ul> <li>Activation/deactivation of IO Devices</li> </ul>	Yes
<ul> <li>— Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8
— Updating time	The minimum value of the update time also depends on the communication component set for PROFINET IO, on the number of IO devices and the quantity of configured user data.
	and and quantity of configured door data.

PROFINET IO Device	
Services	
— PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
— Isochronous mode	No
— IRT	No
— PROFlenergy	Yes
— Shared device	Yes
<ul> <li>Number of IO Controllers with shared device,</li> </ul>	2
max.	
Protocols	
Supports protocol for PROFINET IO	Yes
PROFIsafe	No
PROFIBUS	Yes; CM 1243-5 (master) or CM 1242-5 (slave) required
OPC UA	Yes; OPC UA Server
AS-Interface	Yes; CM 1243-2 required
Protocols (Ethernet)	
• TCP/IP	Yes
• DHCP	No
• SNMP	Yes
• DCP	Yes
• DCP • LLDP	Yes
Redundancy mode	
Media redundancy	Voci on MPD redundancy manager and/or MPD aliant
— MRP	Yes; as MRP redundancy manager and/or MRP client
Open IE communication	Vec
• TCP/IP	Yes
— Data length, max.	8 kbyte
<ul> <li>ISO-on-TCP (RFC1006)</li> </ul>	Yes
— Data length, max.	8 kbyte
• UDP	Yes
— Data length, max.	1 472 byte
Web server	
<ul> <li>supported</li> </ul>	Yes
User-defined websites	Yes
OPC UA	
<ul> <li>Runtime license required</li> </ul>	Yes; "Basic" license required
OPC UA Server	Yes; data access (read, write, subscribe), method call, runtime license
	required
- Application authentication	Available security policies: None, Basic128Rsa15, Basic256Rsa15,
	Basic256Sha256
— User authentication	Basic256Sha256 "anonymous" or by user name & password
<ul><li>— User authentication</li><li>— Number of sessions, max.</li></ul>	Basic256Sha256 "anonymous" or by user name & password 10
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> Communication functions / header	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 2 000 Yes
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server methods, max.</li> <li>Number of monitored items, recommended max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> <b>Communication functions / header S7 communication</b>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 2 000 Yes Yes
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> <b>Communication functions / header S7 communication</b> <ul> <li>supported</li> <li>as server</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> <b>Communication functions / header S7 communication</b> <ul> <li>supported</li> <li>as server</li> <li>as client</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes Yes Yes Yes
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> <li>Number of nodes for user-defined server</li> <li>interfaces, max.</li> </ul> Further protocols <ul> <li>MODBUS</li> </ul> <b>Communication functions / header S7 communication</b> <ul> <li>supported</li> <li>as server</li> <li>as client</li> <li>User data per job, max.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes Yes Yes Yes
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> <li>Number of nodes for user-defined server</li> <li>Struther protocols</li> <li>MODBUS</li> </ul> <b>Communication functions / header S7 communication</b> <ul> <li>supported</li> <li>as server</li> <li>as client</li> <li>User data per job, max.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes Yes Yes Yes See online help (S7 communication, user data size) PG Connections: 4 reserved / 4 max; HMI Connections: 12 reserved / 18 max; S7 Connections: 8 reserved / 14 max; Open User Connections:
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> <li>Number of nodes for user-defined server</li> <li>Struther protocols</li> <li>MODBUS</li> </ul> <b>Communication functions / header S7 communication</b> <ul> <li>supported</li> <li>as server</li> <li>as client</li> <li>User data per job, max.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes Yes Yes Yes See online help (S7 communication, user data size) PG Connections: 4 reserved / 4 max; HMI Connections: 12 reserved / 18 max; S7 Connections: 8 reserved / 14 max; Open User Connections: 8 reserved / 14 max; Web Connections: 2 reserved / 30 max; OPC UA
<ul> <li>User authentication</li> <li>Number of sessions, max.</li> <li>Number of subscriptions per session, max.</li> <li>Sampling interval, min.</li> <li>Publishing interval, min.</li> <li>Number of server methods, max.</li> <li>Number of server methods, max.</li> <li>Number of server interfaces, max.</li> <li>Number of server interfaces, max.</li> <li>Number of nodes for user-defined server interfaces, max.</li> <li>Number of nodes for user-defined server</li> <li>Struther protocols</li> <li>MODBUS</li> </ul> <b>Communication functions / header S7 communication</b> <ul> <li>supported</li> <li>as server</li> <li>as client</li> <li>User data per job, max.</li> </ul>	Basic256Sha256 "anonymous" or by user name & password 10 5 100 ms 200 ms 20 1 000 2 2 000 Yes Yes Yes Yes Yes See online help (S7 communication, user data size) PG Connections: 4 reserved / 4 max; HMI Connections: 12 reserved / 18 max; S7 Connections: 8 reserved / 14 max; Open User Connections:

Test commissioning functions	
Status/control	
Status/control variable	Yes
Variables	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
Forcing	
Forcing	Yes
Diagnostic buffer	
present	Yes
Traces	
<ul> <li>Number of configurable Traces</li> </ul>	2
<ul> <li>Memory size per trace, max.</li> </ul>	512 kbyte
Interrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
ERROR LED	Yes
MAINT LED	Yes
Integrated Functions	
Frequency measurement	Yes
controlled positioning	Yes
Number of position-controlled positioning axes, max.	8
Number of positioning axes via pulse-direction interface	Up to 4 with SB 1222
PID controller	Yes
Number of alarm inputs	4
Potential separation	
Potential separation digital inputs	
<ul> <li>Potential separation digital inputs</li> </ul>	500V AC for 1 minute
<ul> <li>between the channels, in groups of</li> </ul>	1
Potential separation digital outputs	
<ul> <li>Potential separation digital outputs</li> </ul>	Relays
<ul> <li>between the channels</li> </ul>	No
<ul> <li>between the channels, in groups of</li> </ul>	2
EMC	
Interference immunity against discharge of static electricity	
Interference immunity against discharge of static	Yes
electricity acc. to IEC 61000-4-2	
— Test voltage at air discharge	8 kV
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul>	8 kV 6 kV
— Test voltage at air discharge     — Test voltage at contact discharge     Interference immunity to cable-borne interference	6 kV
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> </ul>	6 kV Yes
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul>	6 kV
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge</li> </ul>	6 kV Yes Yes
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul>	6 kV Yes Yes
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> <li>Interference immunity against conducted variable disturbance</li> </ul>	6 kV Yes Yes Yes e induced by high-frequency fields
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge         <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity against voltage surge         <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul> </li> <li>Interference immunity against conducted variable disturbance         <ul> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> </li> </ul>	6 kV Yes Yes
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge         <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity against voltage surge         <ul> <li>Interference immunity against voltage surge</li> <li>Interference immunity against conducted variable disturbanc</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> </li> <li>Emission of radio interference acc. to EN 55 011</li> </ul>	6 kV Yes Yes e induced by high-frequency fields Yes
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge         <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul> </li> <li>Interference immunity against conducted variable disturbance         <ul> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> </li> <li>Emission of radio interference acc. to EN 55 011         <ul> <li>Limit class A, for use in industrial areas</li> </ul> </li> </ul>	6 kV Yes Yes e induced by high-frequency fields Yes Yes; Group 1
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> Interference immunity against voltage surge <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul> Interference immunity on supply lines acc. to IEC 61000-4-5 Interference immunity against conducted variable disturbanc <ul> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul>	6 kV Yes Yes e induced by high-frequency fields Yes
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> <li>Interference immunity against conducted variable disturbance</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> <li>Emission of radio interference acc. to EN 55 011</li> <li>Limit class A, for use in industrial areas</li> <li>Limit class of protection</li> </ul>	6 kV Yes Yes e induced by high-frequency fields Yes Yes; Group 1 Yes; When appropriate measures are used to ensure compliance with
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> Interference immunity against voltage surge <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul> Interference immunity on supply lines acc. to IEC 61000-4-5 Interference immunity against conducted variable disturbanc <ul> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul>	6 kV Yes Yes e induced by high-frequency fields Yes Yes; Group 1 Yes; When appropriate measures are used to ensure compliance with
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> <li>Interference immunity against conducted variable disturbance</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> <li>Emission of radio interference acc. to EN 55 011</li> <li>Limit class A, for use in industrial areas</li> <li>Limit class of protection</li> </ul>	6 kV Yes Yes Yes e induced by high-frequency fields Yes Yes; Group 1 Yes; When appropriate measures are used to ensure compliance with the limits for Class B according to EN 55011
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> <li>Interference immunity to cable-borne interference</li> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge         <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> </ul> </li> <li>Interference immunity against voltage surge         <ul> <li>Interference immunity against voltage surge</li> <li>Interference immunity against conducted variable disturbanc 61000-4-5</li> </ul> </li> <li>Interference immunity against conducted variable disturbanc 0.</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> <li>Emission of radio interference acc. to EN 55 011</li> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> <li>Degree and class of protection</li> <li>IP degree of protection</li> </ul>	6 kV Yes Yes Yes e induced by high-frequency fields Yes Yes; Group 1 Yes; When appropriate measures are used to ensure compliance with the limits for Class B according to EN 55011
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> Interference immunity against voltage surge <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul> Interference immunity against conducted variable disturbanc <ul> <li>Interference immunity against conducted variable disturbanc</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul> Degree and class of protection IP degree of protection Standards, approvals, certificates	6 kV Yes Yes Yes e induced by high-frequency fields Yes Yes; Group 1 Yes; When appropriate measures are used to ensure compliance with the limits for Class B according to EN 55011
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> Interference immunity against voltage surge <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul> Interference immunity against conducted variable disturbanc <ul> <li>Interference immunity against conducted variable disturbanc</li> <li>Interference immunity against conducted variable disturbanc</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul> Degree and class of protection IP degree of protection Standards, approvals, certificates CE mark <ul> <li>UL approval</li> <li>CULus</li> </ul>	6 kV Yes Yes Yes e induced by high-frequency fields Yes Yes Yes; Group 1 Yes; When appropriate measures are used to ensure compliance with the limits for Class B according to EN 55011
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> Interference immunity against voltage surge <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-5</li> </ul> Interference immunity against conducted variable disturbanc <ul> <li>Interference immunity against conducted variable disturbanc</li> <li>Interference immunity against conducted variable disturbanc</li> <li>Interference immunity against high-frequency radiation acc. to IEC 61000-4-6</li> </ul> Emission of radio interference acc. to EN 55 011 <ul> <li>Limit class A, for use in industrial areas</li> <li>Limit class B, for use in residential areas</li> </ul> Degree and class of protection IP degree of protection Standards, approvals, certificates CE mark <ul> <li>UL approval</li> <li>cULus</li> <li>FM approval</li> </ul>	6 kV Yes
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> Interference immunity against voltage surge <ul> <li>Interference immunity against voltage surge</li> <li>Interference immunity against conducted variable disturbanc</li> <li>Interference immunity against in industrial areas</li> <li>Limit class A, for use in residential areas</li> </ul> Degree and class of protection Standards, approvals, certificates CE mark <ul></ul>	6 kV Yes
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity against voltage surge</li> <li>Interference immunity against conducted variable disturbanc</li> <li>Interference immunity against in industrial areas</li> <li>Limit class A, for use in residential areas</li> </ul> Degree and class of protection Standards, approvals, certificates CE mark UL approval RCM (form	6 kV Yes
<ul> <li>Test voltage at air discharge</li> <li>Test voltage at contact discharge</li> </ul> Interference immunity to cable-borne interference <ul> <li>Interference immunity on supply lines acc. to IEC 61000-4-4</li> <li>Interference immunity on signal cables acc. to IEC 61000-4-4</li> </ul> Interference immunity against voltage surge <ul> <li>Interference immunity against voltage surge</li> <li>Interference immunity against conducted variable disturbanc</li> <li>Interference immunity against in industrial areas</li> <li>Limit class A, for use in residential areas</li> </ul> Degree and class of protection Standards, approvals, certificates CE mark <ul></ul>	6 kV Yes Yes Yes Yes Ves Ves Ves Ves Ves Ves Ves Ves Ves V

Free fall	
• Fall height, max.	0.3 m; five times, in product package
Ambient temperature during operation	, , , ,
• min.	-20 °C
• max.	60 °C; Number of simultaneously activated inputs or outputs 7 or 5 (no adjacent points) at 60 °C horizontal or 50 °C vertical, 14 or 10 at 55 °C horizontal or 45 °C vertical
<ul> <li>horizontal installation, min.</li> </ul>	-20 °C
<ul> <li>horizontal installation, max.</li> </ul>	60 °C
• vertical installation, min.	-20 °C
<ul> <li>vertical installation, max.</li> </ul>	50 °C
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Air pressure acc. to IEC 60068-2-13	
Operation, min.	795 hPa
<ul> <li>Operation, max.</li> </ul>	1 080 hPa
Storage/transport, min.	660 hPa
Storage/transport, max.	1 080 hPa
Altitude during operation relating to sea level	
Installation altitude, min.	-1 000 m
<ul> <li>Installation altitude, max.</li> </ul>	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
Relative humidity	
<ul> <li>Operation, max.</li> </ul>	95 %; no condensation
Vibrations	
Vibration resistance during operation acc. to IEC 60068-2-6	2 g (m/s <sup>2</sup> ) wall mounting, 1 g (m/s <sup>2</sup> ) DIN rail
Operation, tested according to IEC 60068-2-6	Yes
Shock testing	
<ul> <li>tested according to IEC 60068-2-27</li> </ul>	Yes; IEC 68, Part 2-27 half-sine: strength of the shock 15 g (peak value), duration 11 ms
Pollutant concentrations	
<ul> <li>SO2 at RH &lt; 60% without condensation</li> </ul>	S02: < 0.5 ppm; H2S: < 0.1 ppm; RH < 60% condensation-free
configuration / header	
configuration / programming / header	
configuration / programming / header	Yes
configuration / programming / header Programming language	Yes Yes
configuration / programming / header Programming language — LAD	
configuration / programming / header Programming language — LAD — FBD	Yes
configuration / programming / header Programming language — LAD — FBD — SCL Know-how protection • User program protection/password protection	Yes
configuration / programming / header Programming language — LAD — FBD — SCL Know-how protection	Yes Yes
configuration / programming / header Programming language — LAD — FBD — SCL Know-how protection • User program protection/password protection	Yes Yes Yes
configuration / programming / header Programming language — LAD — FBD — SCL Know-how protection • User program protection/password protection • Copy protection	Yes Yes Yes Yes
configuration / programming / header         Programming language         — LAD         — FBD         — SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Block protection         • protection         • protection	Yes Yes Yes Yes
configuration / programming / header Programming language — LAD — FBD — SCL Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection	Yes Yes Yes Yes
configuration / programming / header         Programming language         — LAD         — FBD         — SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Block protection         • protection         • protection	Yes Yes Yes Yes Yes Yes
configuration / programming / header         Programming language         — LAD         — FBD         — SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Protection of confidential configuration data         • Protection level: Write protection         • Protection level: Complete protection	Yes Yes Yes Yes Yes Yes Yes
configuration / programming / header         Programming language         — LAD         — FBD         — SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Protection of confidential configuration data         • Protection level: Write protection         • Protection level: Read/write protection	Yes Yes Yes Yes Yes Yes Yes Yes
configuration / programming / header         Programming language         — LAD         — FBD         — SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Protection of confidential configuration data         • Protection level: Write protection         • Protection level: Complete protection	Yes Yes Yes Yes Yes Yes Yes Yes
configuration / programming / header         Programming language         — LAD         — FBD         — SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Protection of confidential configuration data         • Protection level: Write protection         • Protection level: Complete protection         • Programming / cycle time monitoring / header	Yes Yes Yes Yes Yes Yes Yes Yes Yes
configuration / programming / header         Programming language         — LAD         — FBD         — SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Protection of confidential configuration data         • Protection level: Write protection         • Protection level: Read/write protection         • Protection level: Complete protection         • Programming / cycle time monitoring / header         • adjustable	Yes Yes Yes Yes Yes Yes Yes Yes Yes
configuration / programming / header         Programming language         — LAD         — FBD         — SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Protection of confidential configuration data         • Protection level: Write protection         • Protection level: Read/write protection         • Protection level: Complete protection         • Protection level: Complete protection         • Dimensions         Width	Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
configuration / programming / header         Programming language         — LAD         — FBD         — SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Protection of confidential configuration data         • Protection level: Write protection         • Protection level: Write protection         • Protection level: Complete protection         • Protection level: Complete protection         • Protection level: Complete protection         • Dimensions         Width         Height	Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
configuration / programming / header         Programming language         — LAD         — FBD         — SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Protection of confidential configuration data         • Protection level: Write protection         • Protection level: Read/write protection         • Protection level: Complete protection         • Programming / cycle time monitoring / header         • adjustable         Dimensions         Width         Height         Depth	Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
configuration / programming / header         Programming language         - LAD         - FBD         - SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Protection of confidential configuration data         • Protection level: Write protection         • Protection level: Read/write protection         • Protection level: Complete protection         • Programming / cycle time monitoring / header         • adjustable         Dimensions         Width         Height         Depth         Weights	Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
configuration / programming / header         Programming language         — LAD         — FBD         — SCL         Know-how protection         • User program protection/password protection         • Copy protection         • Block protection         • Protection of confidential configuration data         • Protection level: Write protection         • Protection level: Read/write protection         • Protection level: Complete protection         • Programming / cycle time monitoring / header         • adjustable         Dimensions         Width         Height         Depth	Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes